

Technical Report

Report No **JLH/R13427**
 Author **J Hollins**
 Date **2nd September 2013**


Manufactured by **Vision Architectural Glazing Installations Ltd**
 Address **Waterhouse Business Centre
 2 Cromar Way
 Chelmsford
 Essex
 CM1 2QE**

System Name **VAGI Rooflight**

Size **1500mm x 1500mm**

Material **Thermally Broken Aluminium Extrusion
 (Grade 6063-T6)**

Test Standards **BS 6375 Part 1:2009, BS EN 12211:2000,
 BS EN 12210:2000, BS EN 1027:2000,
 BS EN 12208:2000, BS EN 12207:2000 &
 BS EN 1026:2000**



Results	Achieved peak test pressure	Classification	Classification according to BS 6375 Part 1:2009
Air Permeability	1050	4	2
Water Tightness	1050	E1050	7A
Wind Resistance	P1: 2000 P2: 1000 P3: 3000	C 5	C 5

Terms of Usage

The front page of this report can be used as a certificate of compliance when read in conjunction with the rest of this report. The full report contains 14 numbered pages and 9 un-numbered pages and contains the following sections:

1. Introduction
2. Summary of Test Results
3. Description of Test Sample
4. Test Arrangement
5. Test Procedures
6. Test Results
- Appendix A - System Drawings

This report and the results shown within are based upon the information, drawings, samples and tests referred to in the report. The results obtained do not necessarily relate to samples from the production line of the above named company and in no way constitute any form of representation or warranty as to the performance or quality of any products supplied or to be supplied by them. Wintech Engineering Ltd or its employees accept no liability for any damages, charges, cost or expenses in respect of or in relation to any damage to any property or other loss whatsoever arising either directly or indirectly from the use of the report.

Author **J Hollins**
 Technical Assistant

Approved by **M Wass**
 Technical Director

This report is copyright and reproduction of this document in whole or any part thereof must not be made without prior written permission from Wintech Engineering Ltd.

Wintech Engineering Ltd, Halesfield 2, Telford, Shropshire, TF7 4QH
 Tel: +44 (0)1952 586580 Fax: +44 (0)1952 586585

